

Approved Backflow Prevention Devices	
Approved Testable RPZ Devices	
For pipes >65mm in diameter approved devices are:	Wilkins Zurn 375 Serie WATTS 4000SS-AUS Series
For pipes 15mm to 50mm diameter approved devices are:	Watts 009 Series Watts LF009 Lead Free Series
	Apollo Series 4A-200
	Wilkins Zurn 375 Series
Approved Testable Double Check Valves	
For pipes >65mm in diameter approved devices are:	Wilkins Zurn 350 Series WATTS 2000SS-AUS Series WATTS 757ISR Series Double Check Valve Assemblies
For pipes 15mm to 50mm diameter approved devices are:	Watts 007 Series Watts LF007 Lead free Series Watts 7R-AUS Series
	Apollo Series 4A-100
	Wilkins Zurn 350 Series

Note: Devices must meet the requirements of the codes and standards listed below;

- AS 2845:2010 Water Supply – Backflow Prevention - Part 1 Materials, Design and Performance Requirements
- NZ Building Code G12 Water Supplies
- G12/AS1 Acceptable Solutions
- PNCC is transitioning towards lead-free products for installation, and preference should be given to products where available