



CENTRAL ENVIRONMENTAL LABORATORIES

Central Environmental Laboratories  
Module 2, Batchelar Agricultural Centre, Batchelar Road  
Palmerston North, 4472  
PO Box 6054 Awapuni Palmerston North, 4412  
New Zealand

## Analytical Report

COA No: 24/05523-1

P: +64 6 351 4475  
E: cenlab@cenlab.co.nz

Palmerston North City Council  
Water Unit  
Private Bag 11034  
Palmerston North

Compliance of samples tested are assessed according to 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022'

Date received: 19/06/2024  
Sample type: Treated

Time received: 15:35

Sampled by: PNCC Sampler  
Order no.: 4064

Sample date: 19/06/2024

Sample	Test	Result	Units	Comments	Uncertainty
<b>24/05523-01</b>		<b>Sample time: 08:26</b>	<b>Order no.: 4061</b>		
Turitea Water Treatment Plant TP00147	Fluoride	0.76	g/m <sup>3</sup>	Complies with MAV of 1.5	
<b>24/05523-02</b>		<b>Sample time: 11:17</b>			
Papaioea Park Bore Station TP00148	Fluoride	0.81	g/m <sup>3</sup>	Complies with MAV of 1.5	
<b>24/05523-03</b>		<b>Sample time: 15:00</b>			
Takaro Bore Station TP00149	Fluoride	0.77	g/m <sup>3</sup>	Complies with MAV of 1.5	
<b>24/05523-04</b>		<b>Sample time: 14:40</b>			
Roberts Line Bore Station TP00150	Fluoride	0.78	g/m <sup>3</sup>	Complies with MAV of 1.5	
<b>24/05523-05</b>		<b>Sample time: 13:00</b>			
Keith Street Bore Station TP02023	Fluoride	0.80	g/m <sup>3</sup>	Complies with MAV of 1.5	
<b>24/05523-06</b>		<b>Sample time: 09:30</b>	<b>Order no.: 4075</b>		
Ashhurst Bore Station TP00158	Fluoride	0.80	g/m <sup>3</sup>	Complies with MAV of 1.5	
<b>24/05523-07</b>		<b>Sample time: 09:50</b>			
Bunnythorpe Bore Station TP01205	Fluoride	0.71	g/m <sup>3</sup>	Complies with MAV of 1.5	

Sample	Test	Result	Units	Comments	Uncertainty
<b>24/05523-08</b>		<b>Sample time: 15:20</b>			
Longburn Bore Station TP00384	Fluoride	0.77	g/m <sup>3</sup>	Complies with MAV of 1.5	

<b>24/05523-09</b>		<b>Sample time: 10:45</b>			
Railway Road Bore Station TP04022	Fluoride	0.83	g/m <sup>3</sup>	Complies with MAV of 1.5	

< is less than > is more than, g/m<sup>3</sup> is equivalent to mg/L and ppm, MAV - Maximum Acceptable Value. GV - Guideline Value

Notes:

**Test Methodology:**

Test Code	Test	Methodology	Detection Limit
F.002CG	Fluoride	APHA 24th Ed. 4110 B	0.1 g/m <sup>3</sup>

Test analysis was initiated on 20/06/2024.



Report released by

**Johan Bosch**  
Principal Analyst

Date: 24 June 2024

**Key Technical Person:**

Carrie-Ann Leighton

This Laboratory is accredited by International Accreditation New Zealand.

Tests and sampling procedures have been performed in accordance with the conditions of our accreditation.

Where not supplied test methods, detection limits and uncertainties are available on request.

When samples are collected by the client or an agent of the client, results reported apply only to samples as received at the Laboratory.

This report shall not be reproduced except in full, without the written approval of this laboratory.

